



FIRE SAFETY CORRECTION NOTICE

FILE NUMBER 04-30-91-0082-00052	PAGE 1	OF 2	PAGE 2
NAME DAA: Orange County Fairgrounds - Equestrian Center	HOURS	MINUTES	
ADDRESS 88 Fair Dr. Costa Mesa CA. 92626			

THE CALIFORNIA HEALTH AND SAFETY CODE AND THE STATE FIRE MARSHAL'S REGULATIONS REQUIRE THE FOLLOWING FIRE SAFETY DEFICIENCIES BE CORRECTED:

On May 14, 2018, an annual fire and life safety inspection was conducted by this office at the above listed State property, accompanied by DSFM Jose Duenas and Jerry Eldridge, Facility Director (714) 474-5983. The deficiencies noted below are specifically for the Maintenance Area building:

During the inspection of the Maintenance Area building, two sleeping rooms and a cooking area were discovered. The sleeping rooms appeared to have been constructed without approval inside of the Maintenance Area building after the approved/permitted construction was completed. Three beds were found in one of the rooms and four beds in the other. The electrical systems are being overloaded in these rooms due to the number of devices powered from a single outlet. No fire protection equipment is provided in this building.

1. 2016 California Fire Code, Section 102.3 Change of Use or Occupancy

a. Sleeping is not permitted in the Maintenance Area building and shall be discontinued immediately. This is an immediate hazard to life and safety. No area shall be used for sleeping unless the building and area are specifically designed and approved for such use.

*Sleeping shall be discontinued and beds shall be removed by end of day on May 15, 2018.

b. Unapproved construction shall be removed from the Maintenance Area building. If approved construction documents cannot be provided to this office, any construction not included on the original approved building plans shall be removed.

*A plan of action shall be provided to this office within 30 days.

c. Use of the stove/oven shall be discontinued. The building is not intended for this use.

2. 2016 California Fire Code, Section 605 Electrical Equipment

The following electrical hazards shall be abated:

a. Remove extension cords used as permanent wiring.

b. Remove multi-plug adaptors.

c. Remove "daisy-chained" power strips. Power strips shall be plugged directly into an approved receptacle.

3. California Code of Regulations Title 19, Div 1, 3.14 Fire Hazard

a. Candles shall be removed from the Maintenance Area building. Open flame and candles are not permitted in this building.

4. California Code of Regulations Title 19, Div 1, 3.11 Exits

a. Relocate the couch partially obstructing the exit door in the Maintenance Area building. Egress shall be maintained free of obstructions.

Unless otherwise noted in this report, deficiencies shall be corrected within 30 days.

----- end of report -----

The above deficiencies are to be corrected within 30 days. When all deficiencies have been corrected, sign and return a copy of the certification to 602 E. Huntington Dr. Ste. A Monrovia, CA 91016 or P.O. Box 944246, Sacramento, CA 94244-2460. If you have any questions, please contact the Office of the State Fire Marshal at 626-261-3756.

DATE:

SIGNATURE:

ISSUED BY (DEPUTY STATE FIRE MARSHAL)

RECEIVED BY

DATE

Michael Slocum 

Jerry Eldridge

May 15, 2018